NYU DORMITORY FIRE SAFETY PLAN FIRE EMERGENCY INFORMATION

THIS FIRE SAFETY PLAN IS INTENDED TO HELP YOU AND YOUR ROOMATES PROTECT YOURSELVES IN THE EVENT OF FIRE. THIS FIRE SAFETY PLAN CONTAINS:

- Basic fire prevention and fire preparedness measures that will reduce the risk of fire and maximize your safety in the event of a fire.
- Basic information about your building, including the type of construction, the different ways of exiting the building and the types of fire safety systems it may have.
- Emergency fire safety and evacuation instructions in the event of fire in your building.

PLEASE TAKE THE TIME TO READ THIS FIRE SAFETY PLAN AND TO DISCUSS IT WITH YOUR ROOMMATES. FIRE PREVENTION, PREPAREDNESS, AND AWARENESS CAN SAVE YOUR LIFE!

IN THE EVENT OF A FIRE:

CALL 911

OR THE FIRE DEPARTMENT DISPATCHER, at:

(212) 999-2222

OR TRANSMIT AN ALARM FROM THE NEAREST FIRE ALARM BOX

BASIC FIRE PREVENTION AND FIRE PREPAREDNESS MEASURES

These are fire safety tips that everybody should follow:

- 1. Every room and/or suite should be equipped with at least one smoke detector. Check them periodically to make sure they work. Most smoke detectors can be tested by pressing the test button. Smoke detectors are either wired electrically operated or battery operated. Replace batteries whenever a smoke detector chirps to signal that its battery is low or in the spring and fall when clocks are moved forward or back one hour. The smoke detector should be replaced on a regular basis in accordance with the manufacturer's recommendation, but at least once every ten years.
- 2. Carelessly handled or discarded cigarettes are the leading cause of fire deaths. Never smoke in bed or when you are drowsy and be especially careful when smoking on a sofa. Be sure that you completely extinguish every cigarette in an ashtray that is deep and won't tip over. Never leave a lit or smoldering cigarette on furniture or unattended.
- 3. Do not leave cooking unattended. Keep stove tops clean and free of items that can catch

- on fire. Before you go to bed, check your kitchen to ensure that your stove and oven is off and any electric coffee or teapot is unplugged.
- 4. Never overload electrical outlets. Replace any electrical cord that is cracked or frayed. Never run extension cords under rugs. Use only power strips with circuit- breakers.
- 5. Keep all doorways and windows leading to fire escapes free of obstructions. Report any obstructions or accumulations of rubbish in the hallways, stairwells, fire escapes or other means of egress.
- 6. Familiarize yourself with the location of all stairwells, fire escapes and other means of egress.
- 7. With your roommate(s), prepare an emergency escape route to use in case of a fire in the building. Choose a meeting place outside the building where you should meet if you are separated during the emergency.

BUILDING INFORMATION

Building Construction

In a fire emergency, all residents of dormitory buildings (traditional or apartment type) <u>are</u> expected to leave their room or suite regardless of the building construction.

Residential buildings built before 1968 are generally classified either as "fireproof" or "non-fireproof." Residential buildings built in or after 1968 are generally classified either as "combustible" or "non-combustible." The type of building construction generally depends on the size and height of the building.

A "non-combustible" or "fireproof" building is a building whose structural components (the supporting elements of the building, such as steel or reinforced concrete beams and floors) are constructed of materials that do not burn or are resistant to fire and therefore will not contribute to the spread of a fire. In such buildings, fires are more likely to be contained in the apartment or space in which they start and less likely to spread inside the building walls to other apartments and floors. **THIS DOES NOT MEAN THAT THE BUILDING IS IMMUNE FROM FIRE**. While the structural components of the building may not catch fire, all of the contents of the building (including furniture, carpeting, wood floors, decorations and personal belongings) may catch fire and generate flame, heat and/or large amounts of smoke, which can travel throughout the building. Especially if apartment or stairwell doors are left open.

A "combustible" or "non-fireproof" building has structural components (such as wood) that will burn if exposed to fire and can contribute to the spread of a fire. In such buildings, the fire can spread inside the building walls to other rooms and floors, in addition to the flame, heat and smoke that can be generated by the burning contents of the building.

Be sure to check Part I (Building Information Section) of this fire safety plan to see what type of building you occupy.

Means of Egress

All dormitory buildings have at least one means of egress (way of exiting the building), and most have at least two. There are several different types of egress:

Interior Stairs - All buildings have stairs leading to the street level. These stairs may be enclosed or unenclosed. Unenclosed stairwells (stairs that are not separated from the hallways by walls and doors) do not prevent the spread of flame, heat and smoke. Since flame, heat and smoke generally rise, unenclosed stairs may not ensure safe egress in case of a fire on a lower floor. Enclosed stairs are more likely to permit safe egress from the building, if the doors are kept closed. It is important to get familiar with the means of egress available in your building.

Exterior Stairs - Some buildings provide access to the apartments by means of stairs and corridors that are outdoors. The fact that they are outdoors and do not trap heat and smoke enhances their safety in the event of a fire. Provided that they are not obstructed.

Fire Tower Stairs - These are generally enclosed stairwells in a "tower", separated from the building by airshafts open to the outside. The open-air shafts allow heat and smoke to escape from the building.

Fire Escapes - Older buildings may be equipped with a fire escape on the outside of the building, which is accessed through a window or balcony. Fire escapes are considered a "secondary" or alternate means of egress and are to be used if the primary means of egress (stairwells) cannot be safely used to exit the building, because they are obstructed by flame, heat or smoke.

Exits - Most buildings have more than one exit. In addition to the main entrance to the building, there may be separate side exits, rear exits, basement exits, roof exits and exits to the street from stairwells. Some of these exits may have alarms. Not all of these exits may lead to the street. Roof exits may or may not allow access to adjoining buildings.

Be sure to review Part I (Building Information Section) of this fire safety plan and familiarize yourself with the different means of egress from your building.

Fire Sprinkler Systems

A fire sprinkler system is a system of pipes and sprinkler heads that when triggered by the heat of a fire automatically discharges water that extinguishes or controls the fire. The sprinkler system will continue to discharge water until it is turned off. When a sprinkler system activates, an alarm is sounded throughout the building and <u>automatically transmitted to the Fire Department</u> by way of a Central Station.

Sprinkler systems are very effective at preventing fire from spreading beyond the room in which it starts. However, the fire may still generate smoke, which can travel throughout the building.

Dormitory buildings have been required to have fire sprinkler systems in compactor chutes and rooms, storage rooms, boiler rooms and public areas. However, all dormitory buildings constructed or substantially renovated after March 1999, are required by law to be equipped with a fire sprinkler system throughout the building.

Be sure to review Part I (Building Information Section) of this fire safety plan to learn whether your building is equipped with fire sprinkler systems.

Interior Fire Alarm Systems

All dormitory buildings are equipped with interior fire alarm systems that are designed to warn building occupants of a fire in the building. Generally, these systems are manually activated (must be pulled by hand) and do automatically transmit a signal to the Fire Department by way of a Central Station.

Such interior fire alarm systems generally consist of a panel located in a lobby or basement, with manual pull stations located near the main entrance and by each stairwell door.

Be sure to review Part I (Building Information Section) of this fire safety plan to familiarize yourself with the location of the manual pull stations and how to activate them in the event of a fire.

Public Address Systems

Although generally not required, some dormitory buildings may be equipped with public address systems that enable voice communications from a central location, usually in the building lobby. Public address systems are different from building intercoms, and usually consist of loudspeakers in building hallways and/or stairwells.

Be sure to review Part I (Building Information Section) of this fire safety plan to learn whether your building is equipped with a public address system.

EMERGENCY FIRE SAFETY AND EVACUATION INSTRUCTIONS

IN THE EVENT OF A FIRE, FOLLOW THE DIRECTIONS OF FIRE DEPARTMENT PERSONNEL. HOWEVER, THERE MAY BE EMERGENCY SITUATIONS IN WHICH YOU MAY BE REQUIRED TO DECIDE ON A COURSE OF ACTION TO PROTECT YOURSELF AND THE OTHER MEMBERS OF YOUR RESIDENCE.

THIS FIRE SAFETY PLAN IS INTENDED TO ASSIST YOU IN SELECTING THE SAFEST COURSE OF ACTION IN SUCH AN EMERGENCY. PLEASE NOTE THAT NO FIRE SAFETY PLAN CAN ACCOUNT FOR ALL OF THE POSSIBLE FACTORS AND CHANGING CONDITIONS; YOU WILL HAVE TO DECIDE FOR YOURSELF WHAT IS THE SAFEST COURSE OF ACTION UNDER THE CIRCUMSTANCES.

General Emergency Fire Safety Instructions

- 1. Keep calm. Do not panic. Notify the Fire Department as soon as possible. Fire Department personnel will be on the scene of a fire within minutes of receiving an alarm.
- 2. Because flame, heat and smoke rise, generally a fire on a floor below your room or apartment presents a greater threat to your safety than a fire on a floor above.
- 3. Do not overestimate your ability to put out a fire. Most fires cannot be easily or safely extinguished alone. Do not attempt to put a fire out once it begins to quickly spread. If you attempt to put a fire out, make sure you have a clear path of retreat from the room.
- 4. When exiting the building during a fire, close all doors as you exit to confine the fire. **Never use the elevator**. It could stop between floors or take you to where the fire is.
- 5. Heat, smoke and gases emitted by burning materials can quickly choke you. If you are caught in a heavy smoke condition where visibility is poor, get down on the floor and crawl. Take short breaths, breathing through your nose.
- 6. If your clothes catch fire, don't run. Stop where you are, drop to the ground, cover your face with your hands to protect your face and lungs and roll over to smother the flames.

Evacuation Instructions In The Event of a Fire In Your Room or Suite

- 1. Close the door to the room in which the fire started.
- 2. Make sure that **everyone** leaves the apartment. Stay low when exiting.
- 3. Close the apartment door but do not lock it.
- 4. Alert people on your floor by knocking on doors on your way to the exit.
- 5. Activate the interior fire alarm pull station on your floor.
- 6. Use the nearest safe stairwell to exit the building.

7. **Do Not Use the Elevators**.

- 8. Once arriving at a safe location below the fire floor or the street, call 911 or transmit an alarm from a fire alarm box to report the fire. Do not assume that the fire has been reported unless you see Fire Department personnel on the scene.
- 9. Meet your roommates at a predetermined location outside. Notify responding Fire Department personnel if anyone is unaccounted for.

Evacuation Instructions In The Event of A Fire In Your Building But Not In Your Room or Suite

- 1. Feel your apartment door and doorknob with the back of your hand. If they are not hot, open the door slightly to check if there is any flame or smoke in the hallway.
- 2. Exit your apartment or building if you can safely do so. Follow the instructions for a "fire in your room."
- 3. If the hallway or staircase is not safe for egress (because of flame, heat or heavy smoke conditions) and your have access to a fire escape, use it to exit the building.
- 4. If you cannot safely exit your room or building because your apartment door is hot, or because fire, heat or smoke conditions prevent safe egress, call 911 or the Fire Department dispatcher, and inform them of your situation. Provide your room number and the number of persons present in your room or suite.
 - A. If the door is hot or is there is smoke in your hallway or coming into your apartment, seal the front door with wet sheets or towels, seal air ducts and any other openings where smoke may enter. Wet down the apartment door if gets hot. Turn off all air conditioners.
 - B. Open windows a few inches at the top and bottom unless flames or smoke is coming from below. Do not break any windows. They may need to be closed at a later time.
 - C. If conditions in the apartment appear life threatening, open a window and wave a bedsheet or towel side-to-side to attract the attention of firefighters.
 - D. If possible, retreat to a balcony or terrace away from the source of the flames, heat or smoke.

NYU DORMITORY FIRE SAFETY PLAN BUILDING INFORMATION SHEET 240 MERCER STREET

| Address: 70 Washington Square South New York, New York 10003 Telephone: 212-998-1212 BUIL DING INFORMATION: Year of Construction: 1981 Type of Construction: ≤ Combustible | | G OWNER: | | | | | | | | |
|---|--|--|--|--|--|---|--|--|--|--|
| Telephone: New York, New York 10003 | | | New York University | | | | | | | |
| BUILDING INFORMATION: Year of Construction: 1981 Type of Construction: ≤ Combustible Number of Floors: 20_ Aboveground 1_ Belowground Sprinkler System: Yes ≤ No Sprinkler System Coverage: Entire Building Partial (complete all that apply) All kitchens and bedrooms All kitchens and bedrooms All hallways: All hallways, common areas, and half of cellar hallway ≤ Stairwells: Yes Compactor Chute: Yes Till Floor Mail Room, Supervisors Office Fire Alarm: Yes Location of Manual Pull Stations: 1st Floor and cellar: near all exits 2nd – 6th floor: 4 per floor: 4 per floor: 4 per floor: 2 per floor Public Address System: Yes No No Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Identification Location Leads to Enclosed interior Stair A Cellar - 20th Floor w/roof access Afrecer St. Enclosed interior Stair B Cellar - 2 | Address: | ess: 70 Washington Square South | | | | | | | | |
| Partial (complete all that apply) Partial (complete all that apply) | | New York, N | ew York 10003 | | | | | | | |
| Year of Construction: 1981 Type of Construction: ≤ Combustible Number of Floors: 20 Aboveground Sprinkler System: Yes ≤ No Sprinkler System Coverage: Entire Building Dwelling Units: All kitchens and bedrooms All hallways: All hallways, common areas, and half of cellar hallway ≤ Stairwells: Yes Compactor Chute: Yes Tist Floor Mail Room, Supervisors Office Fire Alarm: Yes Location of Manual Pull Stations: 1st floor and cellar: near all exits 2nd - 6th floor: 4 perfloor: 4 perfloor Public Address System: ≤ Yes No Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Identification Location Leads to Enclosed interior Stair A Cellar - 20th Floor w/ roof access Mercer St. Enclosed interior Stair B Cellar - 20th Floors w/ roof access Mercer St. Enclosed interior Stair C 1st - 6th Floors w/ roof access Mercer St | Telephone: | 212-998-1212 | 2 | | | | | | | |
| Year of Construction: 1981 Type of Construction: ≤ Combustible Number of Floors: 20 Aboveground Sprinkler System: Yes ≤ No Sprinkler System Coverage: Entire Building Dwelling Units: All kitchens and bedrooms All hallways: All hallways, common areas, and half of cellar hallway ≤ Stairwells: Yes Compactor Chute: Yes Tist Floor Mail Room, Supervisors Office Fire Alarm: Yes Location of Manual Pull Stations: 1st floor and cellar: near all exits 2nd - 6th floor: 4 perfloor: 4 perfloor Public Address System: ≤ Yes No Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Identification Location Leads to Enclosed interior Stair A Cellar - 20th Floor w/ roof access Mercer St. Enclosed interior Stair B Cellar - 20th Floors w/ roof access Mercer St. Enclosed interior Stair C 1st - 6th Floors w/ roof access Mercer St | BUILDING | G INFORMATIO | ON: | | | | | | | |
| Number of Floors: 20 Aboveground 1 Belowground Sprinkler System: ☑ Yes ≤ No Sprinkler System Coverage: ☑ Entire Building Partial (complete all that apply) | | | | | | | | | | |
| Sprinkler System Coverage: ⊠ Entire Building Partial (complete all that apply) ⊠ Dwelling Units: All kitchens and bedrooms ⊠ Hallways: All hallways, common areas, and half of cellar hallway ≤ Stairwells: □ Compactor Chute: □ Stairwells: □ Compactor Chute: □ Stairwells: □ Compactor Chute: □ Stairwells: □ S | Type of Co | nstruction: | ≤ Combustibl | e | ⊠ Non-Con | nbustible | | | | |
| Sprinkler System Coverage: | Number of | Floors: | 20_ Aboveground | | 1 Belowground | | | | | |
| Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Means of Egress Identification Location Location Enclosed interior Stair B Cellar - 20 th Floor w/ roof access Mercer St. All kitchens and bedrooms All hallways: All kitchens and bedrooms All hallways; common areas, and half of cellar hallway All hallways: All hallways, common areas, and half of cellar hallway All hallways: All hallways, common areas, and half of cellar hallway Yes | Sprinkler S | ystem: | ĭ Yes | | ≤No | | | | | |
| Stairwells: ☐ Compactor Chute: ☐ Yes ☐ Other: ☐ Yes ☐ Other: ☐ Yes ☐ Other: ☐ 1 st Floor Mail Room, Supervisors Office Fire Alarm: ☐ Yes ☐ Transmits Alarm to Fire Dept/Fire Alarm CO ≤ No ☐ Location of Manual Pull Stations: ☐ 1 st floor and cellar: near all exits 2 nd - 6 th floor: 4 per floor Public Address System: ☐ Yes ☐ No ☐ Location of Speakers:: ☐ Yes ☐ No ☐ Location Unit ☐ Other ☐ Other ☐ Type of Egress ☐ Identification ☐ Location ☐ Leads to ☐ Enclosed interior Stair ☐ A ☐ Cellar - 20 th Floor w/ roof access ☐ 3 rd street ☐ Enclosed interior Stair ☐ B ☐ Cellar - 20 th Floor w/ roof access ☐ Mercer St. ☐ Enclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. ☐ Inclosed interior Stair ☐ C ☐ 1 st - 6 th Floor w/ roof access ☐ Mercer St. | • | • | | | Partial (co | mplete all that apply) | | | | |
| Section Sec | X | Hallways: | All hallway | s, common areas, and | half of cellar | hallway | | | | |
| Section Sec | < s | tairwells: | | · · · · · · · · · · · · · · · · · · · | | | | | | |
| Some Description | | | Ves | | | | | | | |
| Fire Alarm: | | - | | oil Doom Supervisor | os Offica | | | | | |
| Location of Manual Pull Stations: floor 7 th −8 th floors: 3 per floor Public Address System: Location of Speakers:: ≤ Yes Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Type of Egress Enclosed interior Stair A Cellar − 20 th Floor w/ roof access Enclosed interior Stair B Cellar − 20 th Floor w/ roof access Mercer St. Enclosed interior Stair C 1 st floor and cellar: near all exits 2 nd − 6 th floor: 4 per | | Other. | 1 11001 111 | an Koom, Supervisor | 8 Office | | | | | |
| Location of Manual Pull Stations: floor 7 th −8 th floors: 3 per floor Public Address System: Location of Speakers:: ≤ Yes Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Type of Egress Enclosed interior Stair A Cellar − 20 th Floor w/ roof access Enclosed interior Stair B Cellar − 20 th Floor w/ roof access Mercer St. Mercer St. Mercer St. | Fire Alarm | | Vac V | Transmits Alarm to | Fire Dent/Fir | a Alarm CO No | | | | |
| floor 7 th −8 th floors: 3 per floor Public Address System: ≤ Yes Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Enclosed interior Stair A Cellar − 20 th Floor w/ roof access Enclosed interior Stair B Cellar − 20 th Floor w/ roof access Mercer St. Enclosed interior Stair C 1 st − 6 th Floors w/ roof access Mercer St. | | | | | _ | | | | | |
| Public Address System: \leq Yes Location of Speakers:: \leq Staircase \leq Hallway \leq Dwelling Unit \leq Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): $ \frac{\text{Type of Egress}}{\text{Enclosed interior Stair}} \frac{\text{Identification}}{A} \frac{\text{Location}}{\text{Cellar} - 20^{\text{th} Floor w/ roof access}} \frac{\text{J}^{\text{rd}}}{\text{Street}} \\ \frac{\text{Enclosed interior Stair}}{\text{Enclosed interior Stair}} \frac{\text{B}}{\text{Cellar} - 20^{\text{th} Floor w/ roof access}} \frac{\text{Mercer St.}}{\text{Enclosed interior Stair}} \\ \frac{\text{Enclosed interior Stair}}{\text{C}} \frac{\text{C}}{\text{I}^{\text{st}} - 6^{\text{th} Floors w/ roof access}} \frac{\text{Mercer St.}}{\text{Mercer St.}} $ | | | | | | all exits $2-6$ floor: 4 per | | | | |
| Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Identification Enclosed interior Stair Location Location Location Enclosed interior Stair Leads to A Cellar - 20 th Floor w/ roof access 3 rd street Enclosed interior Stair B Cellar - 20 th Floor w/ roof access Mercer St. Enclosed interior Stair C 1 st - 6 th Floors w/ roof access Mercer St. | | or $7^{\circ\circ}$ –8°° floors: | 3 per floor | 9 th -20 th floo | ors: 2 per floor | r | | | | |
| Location of Speakers:: ≤ Staircase ≤ Hallway ≤ Dwelling Unit ≤ Other Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress Identification Location Enclosed interior Stair A Cellar - 20 th Floor w/ roof access 3 rd street Enclosed interior Stair B Cellar - 20 th Floor w/ roof access Mercer St. Enclosed interior Stair C 1 st - 6 th Floors w/ roof access Mercer St. | | | | | _ | 7 | | | | |
| Means of Egress (e.g., Unenclosed/Enclosed Interior Stairs, Exterior Stairs, Fire Tower Stairs, Fire Escapes, Exits): Type of Egress | floo | | | ≤ Yes | | ⊠ No | | | | |
| | floo Public Add | ress System: | | | | | | | | |
| | floo Public Add | ress System: | | case ≤ Hallway | | | | | | |
| | floo Public Add | ress System: | | case ≤ Hallway | | | | | | |
| | Public Add Loc | ress System: cation of Speakers:: | ≤ Stairc | • | ≤ Dwelling | g Unit ≤ Other | | | | |
| | Public Add Loc | ress System: cation of Speakers:: | ≤ Stairc | • | ≤ Dwelling | g Unit ≤ Other | | | | |
| Enclosed interior Stair B Cellar -20^{th} Floor w/ roof access Mercer St. Enclosed interior Stair C $1^{st} - 6^{th}$ Floors w/ roof access Mercer St. | Public Add Loc Means of E | ress System: cation of Speakers:: gress (e.g., Unenclo | ≤ Staird | ior Stairs, Exterior Stairs, | ≤ Dwelling | g Unit ≤ Others, Fire Escapes, Exits): | | | | |
| Enclosed interior Stair C $1^{st} - 6^{th}$ Floors w/ roof access Mercer St. | Public Add Loc Means of E | ress System: cation of Speakers:: gress (e.g., Unenclo | ≤ Staird sed/Enclosed Interi Identification | ior Stairs, Exterior Stairs, | ≤ Dwelling Fire Tower Stairs | g Unit ≤ Others, Fire Escapes, Exits): | | | | |
| | Public Add Loc Means of E | ress System: cation of Speakers:: gress (e.g., Unenclo pe of Egress losed interior Stair | ≤ Staird sed/Enclosed Interi Identification A | ior Stairs, Exterior Stairs, Location Cellar – 20 th Floor w/ | ≤ Dwelling Fire Tower Stairs roof access | g Unit ≤ Others, Fire Escapes, Exits): Leads to3 rd street | | | | |
| | Public Add Loc Means of E Ty Encl Encl | ress System: cation of Speakers:: gress (e.g., Unenclo pe of Egress losed interior Stair | ≤ Staird sed/Enclosed Interi Identification A B | Location Cellar – 20 th Floor w/ Cellar – 20 th Floor w/ 1st – 6 th Floors w/ roof | ≤ Dwelling Fire Tower Stairs roof access roof access raccess | g Unit ≤ Others, Fire Escapes, Exits): Leads to3 rd streetMercer St. | | | | |
| Enclosed interior Stair E Cellar – 1 st lobby | Public Add Loc Means of E Ty Encl Encl Encl | ress System: cation of Speakers:: gress (e.g., Unenclo pe of Egress losed interior Stair losed interior Stair | ≤ Staird sed/Enclosed Interi Identification A B C | Location Cellar – 20 th Floor w/ Cellar – 20 th Floor w/ 1st – 6 th Floors w/ roof 1st – 8 th Floors w/ roof | ≤ Dwelling Fire Tower Stairs roof access roof access raccess | g Unit ≤ Others, Fire Escapes, Exits): Leads to3 rd streetMercer St. | | | | |
| | Public Add Loc Means of E Ty Encl Encl Encl Encl | ress System: cation of Speakers:: gress (e.g., Unenclo pe of Egress losed interior Stair losed interior Stair losed interior Stair | ≤ Staird sed/Enclosed Interi Identification A B C D | Location Cellar – 20 th Floor w/ Cellar – 20 th Floor w/ 1st – 6 th Floors w/ roof 1st – 8 th Floors w/ roof | ≤ Dwelling Fire Tower Stairs roof access roof access Faccess | g Unit ≤ Others, Fire Escapes, Exits): Leads tostreet Mercer StMercer St Mercer St | | | | |

DATE PREPARED: July 12, 2016

NYU DORMITORY FIRE SAFETY PLAN BUILDING INFORMATION SHEET D'AGOSTINO HALL

| | UILDING DDRESS: 110 West 3 rd Street, New York, NY 10012 (D'Agostino Hall) | | | | | | | | |
|--|---|--|-------------------------------------|---------------------------------|---|---|--|--|--|
| DIM D | | | | | | | | | |
| BUILD Name: | ING OWNER: | [Imirromaitry | | | | | | | |
| Address | | New York University 70 Washington Square South | | | | | | | |
| Address | | | • | | | | | | |
| Talanka | | New York, NY 10003 | | | | | | | |
| Telepho | one: 212-996-121 | | | | | | | | |
| BUILD | ING INFORMATI | | | | | | | | |
| Year of | Construction: | 1986 | _ | | | | | | |
| Type of | Construction: | ≤ Combustible | ≤ Combustible | | ⊠ Non-Combustible | | | | |
| Number | r of Floors: | 14 Ab | 14 Aboveground | | 2Belowground | | | | |
| Sprinkle | er System: | ĭ Yes | | ≤No | | | | | |
| Sprinkle | er System Coverage: | | = | Partial (complete | te all that apply) | | | | |
| | ✓ Dwelling Units: | All kitchens an $2^{nd} - 14^{th}$ floors | | | | | | | |
| | ★ Hallways: | 2 - 14 HOOR | S | | | | | | |
| | ≤ Stairwells: | 37 | | | | | | | |
| ✓ Compactor Chute: Yes ✓ Other: Cellar, Sub-cellar, 1st floor, mezzanine, 12th floor laundry, roof mech. Room | | | | | | | | | |
| | ĭ Other: | Cellar, Sub-cel | lar, 1 st floor, mezzai | nine, 12 th floor la | undry, roof mech. Room | | | | |
| Fire Ala | arm: Location of Manual P | | Transmits Alarm to _Two pull statio | - | Alarm CO ≤ No ar each stairwell door | | | | |
| _ | | | | | | | | | |
| Public Address System: ≤ Yes ⊠ No | | | | | | | | | |
| | Location of Speakers: | : ≤ Stairca | ase ≤ Hallway | ≤ Dwelling Ur | nit ≤ Other | | | | |
| _ | | | • | | | | | | |
| Means | of Egress (e.g., Unencl | osed/Enclosed Interio | r Stairs, Exterior Stairs, | Fire Tower Stairs, Fi | re Escapes, Exits): | | | | |
| Γ | Type of Egress | Identification | Location | Ţ | Leads to | 7 | | | |
| _ | Enclosed, interior | A | Roof - Sub-cellar | | Courtyard and Macdougal St. | | | | |
| | Enclosed, interior | В | Roof - Sub-cellar | | Street | T | | | |
| | | _ | | | |] | | | |
| | | | | | | 4 | | | |
| | | | | | | - | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| Other Information: Emergency lighting is provided in hallway and corridors | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| DATE | DDEDADED Luk | 11, 2016 | | | | | | | |
| DAIEI | PREPARED: July | 11,2010 | | | | | | | |

BUILDING INFORMATION SHEET

| BUILDING ADDRESS: <u>130 MacDo</u> | ugal Street | | | |
|---|-------------------------|--------------------------------|-----------------------------------|--|
| BUILDING OWNER: Name: New York Univ Address: 70 Washington New York, NY Telephone: 212,998,1212 | Sq. South | | | |
| BUILDING INFORMAT | <u>ION</u> | | | |
| Year of Construction: | <u>1900-10's</u> | | | |
| Type of Construction: | X Comb | ustible | Non-Combustible | |
| Number of Floors: | 3 Abovegrou | ınd <u>2</u> | 2 Belowground | |
| Sprinkler System: | Yes | [| X No | |
| Sprinkler System Coverage: E Dwelling Units: Hallways Stairwells: Compactor Chute: Other: | Entire Building | Partial (o | complete all that apply) | |
| Fire Alarm: Location of Manual Pull Stations | | smits Alarm to Fire | Dept/Fire Alarm Co. X No | |
| Public Address System: Location of Speakers: Stairs | Yes case Hally | X No Dwelling | Unit Other | |
| Means of Egress (e.g., Unenclosed | d/Enclosed Interior Sta | airs, Exterior Stairs, Fire To | wer Stairs, Fire Escapes, Exits): | |
| Type of Egress Identific | ation | Location | Leads to | |
| Center Stairs | | Middle of Building | Street | |
| Other Information: | | | | |

DATE PREPARED: 7/11/2016